

**Type Test Certificate of** Dielectric performance and Short-Circuit performance

**Apparatus** Three-pole medium voltage air insulated earthing switch fitted in a metal-enclosed switchgear and controlgear

**Designation** ES-17.5/40-210

Rated voltage 12 kV ; Rated normal current 2000 A ; Rated frequency 50/60 Hz

**Manufacturer** Eaton Corporation  
1000 Cherrington Parkway, Moon Township, PA 15108 - USA

**Client** Eaton Corporation  
1000 Cherrington Parkway, Moon Township, PA 15108 - USA

**Tested by** CESI S.p.A. - Milan, ITALY

**Tests date** from September 25, 2012 to February 28, 2013

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-102 (2012-02)  
Sub-clauses 6.2.6, 6.6 and 6.101

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 5 **No. of pages annexed** -

**Issue date** September 2, 2013

**Prepared** PSV - Beccarini Pierangelo  
B3022506 2925 AUT

**Verified** PMV - Magistris Paolo, PSV - Vidori Mauro  
B3022506 3845 VER B3022506 2158654 VER

**Approved** PMI - The Manager - Arcidiaco Lorenzo  
B3022506 821814 APP

**CESI** S.p.A.  
Testing & Certification Division  
Testing Operations Area  
"Milan Platform"  
Manager