

TYPE TEST CERTIFICATE

APPROVED

B3022570

Type Test Certificate of Dielectric performance

Apparatus Three-pole medium voltage air insulated earthing switch fitted in a metal-enclosed switchgear and controlgear

Designation ES-17,5/50-210

Rated voltage 17,5 kV ; Rated normal current 2000 A ; Rated frequency 50/60 Hz

Manufacturer Eaton Corporation
1000 Cherrington Parkway, Moon Township, PA 15108 - USA

Client Eaton Corporation
1000 Cherrington Parkway, Moon Township, PA 15108 - USA

Tested by CESI S.p.A. - Milan, ITALY

Tests date from February 22, 2013 to February 22, 2013

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-102 (2012-02)
Sub-clause 6.2.6 and 6.2.10

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 4 **No. of pages annexed** -

Issue date September 3, 2013

Prepared PSV - Beccarini Pierangelo
B3022570 2925 AUT

Verified PMV - Magistris Paolo, PSV - Vidori Mauro
B3022570 3845 VER B3022570 2158654 VER

Approved PMI - The Manager - Arcidiaco Lorenzo
B3022570 821814 APP

CESI S.p.A.
Testing & Certification Division
Testing Operations Area
"Milan Platform"
Manager