

**Type Test Certificate of** Complete type tests

**Apparatus** Line trap

**Designation** LINE TRAP 1250/1600\_0,5 (40KA)

Power frequency inductance: 0,5 mH ; Continuous rated current: 1600 A ; Rated frequency: 50 Hz

**Manufacturer** SELTA S.p.A. - Cadeo (PC) - Italy

**Client** SELTA S.p.A. - Cadeo (PC) - Italy

**Tested by** CESI S.p.A. Milan, Italy

**Tests date** from February 22, 2013 to November 8, 2013

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

**IEC 60353 (1989) with amendment 1 (2002)**

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 4 **No. of pages annexed** -

**Issue date** February 6, 2014

**Prepared** PSV - Beccarini Pierangelo  
B4003215 2905 AUT

**Verified** PHV - Faccheni Fabio, PSV - Colombo Piero  
B4003215 3081 VER B4003215 2158654 VER

**Approved** PMI - The Manager - Arcidiaco Lorenzo  
B4003215 821814 APP

**CESI** S.p.A.  
Testing & Certification Division  
Testing Operations Area  
"Milan Platform"  
Manager