

**Type Test Certificate of** Dielectric performance and short-circuit performance

**Apparatus** Oil-immersed power transformer

**Designation** 33152245

Rated power 315 kVA ; Rated voltages 22/0,4 kV ; Rated frequency 50 Hz

**Manufacturer** QTC Energy Public Company Limited  
2/2 Soi Krungthep Kritha 8(5), Huamark, Bangkok, 10240 Bangkok – Thailand

**Client** QTC Energy Public Company Limited  
2/2 Soi Krungthep Kritha 8(5), Huamark, Bangkok, 10240 Bangkok – Thailand

**Tested by** CESI S.p.A. Milan, Italy

**Tests date** from May 19, 2014 to May 23, 2014

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60076-3 (2013) - Clause 13.2  
IEC 60076-5 (2006) - Clause 4.2

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 4 **No. of pages annexed** -

**Issue date** August 25, 2014

**Prepared** PSV - Beccarini Pierangelo  
B4020106 2925 AUT

**Verified** PMV - Magistris Paolo, PSV - Colombo Piero  
B4020106 3845 VER B4020106 2158654 VER

**Approved** PMI - The Manager - Arcidiaco Lorenzo  
B4020106 821814 APP

**CESI** S.p.A.  
Testing & Certification Division  
Testing Operations Area  
"Milan Platform"  
Manager