

Type Test Certificate of	Dielectric Performance, Temperature Rise Performance and Breaking Performance	
Apparatus	Class A distribution drop-out fuse-cutout for outdoor installation type FSC with porcelain insulator fuse-base (CD 660 mm)	
Designation	FSC	
	Rated voltage 13,8 kV ; Rated normal current 100 A ; Rated frequency 60 Hz	
Manufacturer	Zhejiang Fuerte Electrical Apparatus Co., Ltd. No.508 Baixiang Ave, BeiBaixiang Town, Yueqing, Zhejiang province, China	
Client	Zhejiang Fuerte Electrical Apparatus Co., Ltd. No.508 Baixiang Ave, BeiBaixiang Town, Yueqing, Zhejiang province, China	
Tested by	CESI S.p.A. - Milan, ITALY	
Tests date	from July 29, 2014	to September 8, 2014

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60282-2 (2008-04)
Clauses 8.4, 8.5 and 8.6

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 5 **No. of pages annexed** -

Issue date October 21, 2014

Prepared PSV - Beccarini Pierangelo
B4024480 2925 AUT

Verified PMV - Magistris Paolo, PSV - Colombo Piero
B4024480 3845 VER B4024480 2158654 VER

Approved PMI - The Manager - Arcidiaco Lorenzo
B4024480 821814 APP

CESI S.p.A.
Testing & Certification Division
Testing Operations Area
"Milan Platform"
Manager
Lorenzo Arcidiaco

PAD B4024480 (2011381) - CONFIDENTIAL USE

Mod. RPRO v. 8