

<b>Type Test Certificate of</b>	Dielectric Performance, Temperature Rise Performance and Breaking Performance	
<b>Apparatus</b>	Class A distribution drop-out fuse-cutout for outdoor installation type FSC with porcelain insulator fuse-base (CD 660 mm)	
<b>Designation</b>	FSC	
	Rated voltage 36 kV ; Rated normal current 100 A ; Rated frequency 60 Hz	
<b>Manufacturer</b>	Zhejiang Fuerte Electrical Apparatus Co., Ltd. No.508 Baixiang Ave, BeiBaixiang Town, Yueqing, Zhejiang province, China	
<b>Client</b>	Zhejiang Fuerte Electrical Apparatus Co., Ltd. No.508 Baixiang Ave, BeiBaixiang Town, Yueqing, Zhejiang province, China	
<b>Tested by</b>	CESI S.p.A. - Milan, ITALY	
<b>Tests date</b>	from July 29, 2014	to September 8, 2014

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

**IEC 60282-2 (2008-04)**  
**Clauses 8.4, 8.5 and 8.6**

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 5      **No. of pages annexed** -

**Issue date** October 21, 2014

**Prepared** PSV - Beccarini Pierangelo  
B4024481 2925 AUT

**Verified** PMV - Magistris Paolo, PSV - Colombo Piero  
B4024481 3845 VER      B4024481 2158654 VER

**Approved** PMI - The Manager - Arcidiaco Lorenzo  
B4024481 821814 APP

**CESI** S.p.A.  
Testing & Certification Division  
Testing Operations Area  
"Milan Platform"  
Manager  
*Lorenzo Arcidiaco*

PAD B4024481 (2011386) - CONFIDENTIAL USE

Mod. RPRO v. 8