

Type Test Certificate of Switching and Short-circuit performance

Apparatus Three-phase medium voltage SF₆ insulated general purpose switch

Designation TPR6
Rated voltage 17,5 kV ; Rated normal current 630 A ; Rated frequency 60 Hz

Manufacturer SEL S.p.A.
Via Amendola – 51035 Lamporecchio (PT), Italy

Client SEL S.p.A.
Via Amendola – 51035 Lamporecchio (PT), Italy

Tested by CESI S.p.A. - Milan, ITALY

Tests date from March 27, 2014 to June 16, 2014

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-103 (2011-06)
Sub-clauses 6.6 and 6.101

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 4 **No. of pages annexed** -

Issue date October 30, 2014

Prepared PSV - Beccarini Pierangelo
B4025443 2925 AUT

Verified PMV - Magistris Paolo, PSV - Colombo Piero
B4025443 3845 VER B4025443 2158654 VER

Approved PMI - The Manager - Arcidiaco Lorenzo
B4025443 821814 APP

CESI S.p.A.
Testing & Certification Division
Testing Operations Area
"Milan Platform"
Manager
Lorenzo Arcidiaco