

Type Test Certificate

of Complete Type Tests

Test object	Enclosed three-phase dry-type power transformer, with encapsulated windings, for continuous duty, with cooling by air natural convection
Designation	Cast Resin Power Transformer (Model EPE-LL-1000/11) Rated power 1000 kVA ; Rated voltages 11/0,433 kV ; Rated frequency 50 Hz
Manufacturer	EPE Transformer Sdn. Bhd. Lot 6 Jalan Permata 2, Arab Malaysian Industrial Park – Nilai - Negeri Sembilan – 71800 Malaysia
Tested for	EPE Transformer Sdn. Bhd. Lot 6 Jalan Permata 2, Arab Malaysian Industrial Park – Nilai - Negeri Sembilan – 71800 Malaysia
Date(s) of tests	from October 18 to November 6, 2017
Tested by	CESI S.p.A. Via Rubattino 54 20134 Milano - Italy

The test object, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with STL Guides and:

IEC 60076-11 (2004-05)
Clauses 15 to 23 and 25

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on the ratings page. The Certificate applies only to the test object. The responsibility for conformity of any equipment having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 5 sheet in total.

December 22, 2017

Date of issue

Magistris Paolo
B7026514 3845 AUT

STL Member Laboratory

The Manager - Arcidiaco Lorenzo
B7026514 821814 APP

STL Member Document Digitally Signed

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the test object, are permitted without written permission from CESI.
The authenticity of this document is guaranteed by the integrity of hologram.

