## **Test Certificate**

## of Special tests

Document No.	B7026515 Copy No. 1 Number of pages 5
Apparatus	Enclosed three-phase dry-type power transformer, with encapsulated windings, fo continuous duty, with cooling by air natural convection
Designation	Cast Resin Power Transformer (Model EPE-LL-1000/11) Rated power 1000 kVA; Rated voltages 11/0,433 kV; Rated frequency 50 Hz
Serial Number	21701530
Manufacturer	EPE Transformer Sdn. Bhd Lot 6 Jalan Permata 2, Arab Malaysian Industrial Park Nilai - Negeri Sembilan – 71800 Malaysia
Client	EPE Transformer Sdn. Bhd Lot 6 Jalan Permata 2, Arab Malaysian Industrial Park Nilai - Negeri Sembilan – 71800 Malaysia
Tested for	
Date(s) of tests	November, 9 to 28, 2017
Tested by	CESI S.p.A. Via Rubattino 54 20134 Milano - Italy
Test performed	climatic test class C2 environmental test class E2 fire behaviour test class F1

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with:

IEC 60076-11 (2004) Clauses 26.3.2, 27.4 and 28.2 to 28.8

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s). The ratings assigned by the Manufacturer are listed on the ratings page.

The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

December 22, 2017

Date

Magistris Paolo B7026515 3845 AUT Test Engineer in charge The Manager - Arcidiaco Lorenzo
BY026515 821814 APP
Approved By
Document Digitally Signed

Partial reproduction of this document is permitted only with the written permissions from CESI Group. The authenticity of this document is guaranteed by the integrity of hologram.





