

# Test Certificate

## of Special tests

Document No.	B8023042	Copy No.	1	Number of pages	5
Apparatus	Non-Enclosed three-phase dry-type power transformer, with encapsulated windings, for continuous duty, with cooling by air natural convection				
Designation	STC1600A20				
Serial Number					
Manufacturer	Elpro - Energo s.r.o. - Dlouhá 16, 190 00 Praha - Czech Republic				
Client	Elpro - Energo s.r.o. - Dlouhá 16, 190 00 Praha - Czech Republic				
Tested for					
Date(s) of tests	from May 28 to October 19, 2018				
Tested by	CESI S.p.A. Via Rubattino 54 20134 Milano - Italy				
Test performed	Climatic special test C2 class Environmental special test E2 class Fire behaviour special test F1 class				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with:

IEC 60076-11 (2004-05)  
Clauses 26.3.2, 27.4 and 28.3 to 28.8

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s). The ratings assigned by the Manufacturer are listed on the ratings page.  
The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

November 12, 2018

Date	Magistris Paolo B8023042 3845 AUT Test Engineer in charge	The Manager - Arcidiaco Lorenzo B8023042 821814 ASP Approved By
------	---	---

Document Digitally Signed

Partial reproduction of this document is permitted only with the written permissions from CESI Group.  
The authenticity of this document is guaranteed by the integrity of hologram.



# CESI

Trust the Power of Experience