

Copy No. 1

Certificate No B8026490

## **Type Test Certificate**

## of Dielectric Performance.

Test object	Three-phase 72,5 kV 50 kA SF6 (GIS) gas-insulated metal-enclosed circuit-breaker with three-phase in one enclosure and with common operating mechanism. Composed by BSG,BUS,Circuit Breaker, Current Transformers, Disconnectors, Earthing Switchs and Fast Earthing Switch.		
Designation	ZF7C		
	Rated voltage 72,5kV; Rated normal current 3150 A; Rated frequency 50 Hz		
Manufacturer	XI'AN XD Switchgear Electric Co., Ltd China No. 509 Daqing Road 710077 Xi'An, Shaanxi Province - China		
Tested for	XI'AN XD Switchgear Electric Co., Ltd. – China		
Date(s) of tests	October 18-19-20-31 and November 6, 2017		
Tested by	CESI S.p.A. Via R. Rubatti 20134 Milan -		
The test object, co this document has IEC 62271-203 (20 Sub-Clauses 6.2.6	been subjected t	to the series of proving tests in ac	rings and photographs incorporated in cordance with STL Guides and:
The results are shown in the comply with the above Stan The Certificate applies only Manufacturer.	e record of Proving Tests dard(s) and to justify the r to the test object. The res	atings assigned by the Manufacturer as listed on	obtained and the general performance are considered to the ratings page. I the same designations with that tested rests with the
This Certificate comprises	sheet in total.		
February 04, 2019 Date of issue	$\nabla$	Faccheni Fabio B8026499 3081 AUT STL Member Laboratory	The Manager - Arcidiaco Lorenzo B80206900 821014 APP STL Member Document Digitally Signed
Only integral reproduction o are permitted without written The authenticity of this docu	permission from CESI.		on which are stated the endorsed ratings of the test object,
测思 Eleftinotec Sperimenta Talano	NICO		