

Test Certificate

of Special tests

Document No.	B9006990-1	Copy No.	1	Number of pages	5
Apparatus	Non-Enclosed three-phase dry-type power transformer, with encapsulated windings, for continuous duty, with cooling by air natural convection				
Designation	UII/J/18-19/220				
Serial Number	UII/J/18-19/220				
Manufacturer	TMC Transformers (India) Private Limited Sur.No.26 1/2, Part B, Village Khandiwada(ASOJ) - Vadodara-Halol Highway Tal. Waghodia, District Vadodara - Gujarat 391510 INDIA				
Client	TMC Transformers (India) Private Limited Sur.No.26 1/2, Part B, Village Khandiwada(ASOJ) - Vadodara-Halol Highway Tal. Waghodia, District Vadodara - Gujarat 391510 INDIA				
Tested for					
Date(s) of tests	from December 19, 2018 to February 8, 2019				
Tested by	CESI S.p.A. Via Rubattino 54 20134 Milano - Italy				
Test performed	Climatic special test C2 class Environmental special test E2 class Fire behaviour special test F1 class				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with:

IEC 60076-11 (2018-08)
Clauses 14.4.4, 14.4.5 and 14.4.6.2

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s). The ratings assigned by the Manufacturer are listed on the ratings page. The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

April 04, 2019

Date **Maqstris Paolo**
B9006990 3845 AUT
Test Engineer in charge

The Manager - Arcidiaco Lorenzo
B9006990 821814 ASP
Approved By Document Digitally Signed

Partial reproduction of this document is permitted only with the written permissions from CESI Group.
The authenticity of this document is guaranteed by the integrity of hologram.



CESI

Trust the Power of Experience