

Copy No. 1

Certificate No B9018221-1

Type Test Certificate

of Complete Type Tests

Three-pole medium voltage air insulated earthing switch set in a metal-enclosed switchgear and controlgear
ES-12/40-275
Rated voltage 12 kV; Rated current 40 kA; Rated frequency 50/60 Hz
EATON - 1000 Cherrington Parkway, Moon Township, PA 15108-USA
EATON - 1000 Cherrington Parkway, Moon Township, PA 15108-USA
from April 30 to May 07, 2019
CESI S.p.A. Via Rubattino, 54 20134 Milano – Italy
structed in accordance with the description, drawings and photographs incorporated in been subjected to the series of proving tests in accordance with STL Guides and: 18-05)
s been issued by CESI following exclusively the STL Guides.
ecord of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to ard(s) and to justify the ratings assigned by the Manufacturer as listed on the ratings page. the test object. The responsibility for conformity of any equipment having the same designations with that tested rests with the sheet in total.
Ronchegalli Giorgio Berlizzi 223174UT STL Member Laboratory his Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the test object, permission from CESI.
ent is guaranteed by the integrity of hologram.
ACCREDIA INTELIALANO DI ACCREDITAMENTO L'ENTE ITALIANO DI ACCREDITAMENTO LAB Nº 0030 L LAB Nº 0030 L