

STL Type Test Certificate of Short-Circuit Performance

Test object	Single pole of a three pole 252 kV SF6 (GIS) gas-insulated metal- enclosed circuit-breaker with single operating mechanism.
Designation	ZFW52-252(L)/T4000-50 Rated voltage 252kV ; Rated normal current 4000 A ; Rated frequency 50 Hz
Manufacturer	Henan Pingzhi High-Voltage Switchgear Co.,Ltd. No.645 Jianshe East Road High-Tech 467013 Pingdingshan China
Tested for	Henan Pingzhi High-Voltage Switchgear Co.,Ltd. No.645 Jianshe East Road High-Tech 467013 Pingdingshan China
Date(s) of tests	September 28, 2018 to november 05, 2018
Tested by	CESI S.p.a. Via R. Rubattino, 54 20134 Milan, Italy

The test object, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with STL Guides and:

IEC 62271-203 (2011)
Sub Clauses 6.6 and 6.101

This Type Test Certificate has been issued by CESI following exclusively the STL Guides. The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on the ratings page. The Certificate applies only to the test object. The responsibility for conformity of any equipment having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 5 sheet in total.

October 14, 2019

Date of issue

Faccheni Fabio
B9020163 3081 AUT
STL Member Laboratory

The Manager - Arcidiaco Lorenzo
B9020163 821814 APP
STL Member

Document Digitally Signed

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the test object, are permitted without written permission from CESI.
The authenticity of this document is guaranteed by the integrity of hologram.

