

Copy No. 1

Certificate No

C0400263

STL Type Test Certificate

of Dielectric Performance

Test object	Metal-enclosed, air-insulated, AC medium-voltage switchgear and controlgear
Designation	MV CENGAR CP-641 Rated voltage: 12 kV Rated current: 1250 A Rated frequency: 50/60 Hz
Manufacturer	CEN Solutions Ctra. De la Escusa, s/n Polg. Industrial Torrecuellar 41011 Sevilla, SPAIN
Tested for	CEN Solutions Ctra. De la Escusa, s/n Polg. Industrial Torrecuellar 41011 Sevilla, SPAIN
Date(s) of test(s)	19 August 2019
Tested by	IPH Institut „Prüffeld für elektrische Hochleistungstechnik“ GmbH Landsberger Allee 378A 12681 Berlin, GERMANY

The test object, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with STL Guides and: IEC 62271-200: 2011-10, Sub-clause 6.2

This Type Test Certificate has been issued by CESI following exclusively the STL Guides. The results are shown in the record of Proving Tests. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on the ratings page. The Certificate applies only to the test object. The responsibility for conformity of any equipment having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 31 sheet in total.

17.03.2020

Date of issue: 17.03.2020
 Issued by: Gedela Sai Charan, STL Member Laboratory
 Signed by: The Manager - Schiller Rainer, STL Member
 Document Digitally Signed

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the test object, are permitted without written permission from CESI. The authenticity of this document is guaranteed by the integrity of hologram.

IPH Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH is member laboratory of STL and accredited testing laboratory by DAkkS according to EN ISO/IEC 17025:2005. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-PL-12107-01-00. www.dakks.de

PAD C0400263 (2740958) - CONFIDENTIAL USE

