

type test certificate of	Combined test sequence
apparatus	Three-pole air circuit-breaker in withdrawable version
designation	HAT08 rated voltage 440 V; rated normal current 800 A; rated frequency 50 Hz
manufacturer	HYUNDAI HEAVY INDUSTRIES Co. LTD. Industrial & Power Systems - Ulsan (Korea)
tested for	HYUNDAI HEAVY INDUSTRIES Co. LTD. Industrial & Power Systems - Ulsan (Korea)
date(s) of tests	from March 6, 2002 to March 11, 2002
tested by	CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60947-2 (2001-11) Sub-clause 8.3.8

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages	3
issue date	November 20, 2002
prepared	PeC - C. Del Giorgio
verified	PeC - A. Elli
approved	PeC - V. Scarioni

Carlo Del Giorgio
A. Elli

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio