

**type test certificate of** short-circuit performance

**apparatus** oil-immersed transformer

**designation** 32502014  
rated power 250 kVA; rated voltage 22/0,4 kV; rated frequency 50 Hz

**manufacturer** QUALITY TRANSFORMER Co. Ltd. - Bangkok (Thailand)

**tested for** QUALITY TRANSFORMER Co. Ltd. - Bangkok (Thailand)

**date(s) of tests** from June 23 to 25, 2003

**tested by** CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with IEC 60076-5 (2000)

this Type Test Certificate has been issued by CESI following exclusively the STL Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no. 2.

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**no. of pages** 3

**issue date** July 2, 2003

**prepared** PeC - F. Pizzi

**verified** PeC - G. Arneodo

**approved** PeC - V. Scarioni

*F. Pizzi*  
*G. Arneodo*

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio