

test certificate of Electrical Type Tests

apparatus MV, three cores, 6/10 (12) kV, XLPE insulated, copper  
screened power cable

designation TNBD 240 SQMM LEADER CABLE 11 kV 09/2000  
rated voltage 6/10 (12) kV; rated normal current -- A; rated frequency -- Hz

manufacturer LEADER CABLE INDUSTRY BERHAD - Malaysia

tested for LEADER CABLE INDUSTRY BERHAD - Malaysia

date(s) of tests November 28, 2000 to January 30, 2001

the apparatus, constructed in accordance with the description, drawing and photograph incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2 (1998-11)

this type test certificate has been issued by CESI in accordance with the above mentioned standard.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on page no.2.

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.


only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 4

issue date January 31, 2001

prepared PeC - E. Bertani

approved PeC - V. Scarioni

  
**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio