

test certificate of special test to prove suitability to climatic class C2  
 special test to prove suitability to environmental class E2  
 special test to prove suitability to fire behaviour class F1

apparatus dry-type power transformer

designation TDR/630/24/20 B2  
 rated power 630 kVA; rated voltage 20/0.42 kV; rated frequency 50 Hz

manufacturer IMEFY  
 Los Yebenes - TOLEDO

tested for IMEFY

date(s) of tests February 5 to 23, 2001

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

CENELEC HD 464 S1/A2 (1991) annexes ZA and ZB, HD 464 S1/A3 (1992) annex ZC

this test certificate has been issued by CESI in accordance with above mentioned standards.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the manufacturer as listed on page no.2.

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date March 26, 2001

prepared PeC/TEST - M. Bonomelli

verified PeC/TEST - F. Pizzi

approved PeC/TEST - V. Scarioni

M. Bonomelli  
 F. Pizzi

**CESI**  
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
 Business Unit  
 Prove e Componenti  
 Il Responsabile del Laboratorio