

type test certificate of Breaking performance

apparatus Drop out expulsion fuse having fuse holder lined with synthetic arc quenching material

designation C710-713---  
rated voltage 36 kV; rated normal current 100 A; rated frequency 50 Hz

manufacturer HUBBEL Power Systems - Centralia, MO - USA

tested for HUBBEL Power Systems - Centralia, MO - USA

date(s) of tests from March 14, 2001 to March 16, 2001

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60282-2 (1997) Clause 8.6

this Type Test Certificate has been issued by CESI following exclusively the STI Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Report. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date May 18, 2001

prepared PeC - P. BECCARINI

verified PeC - A. GEROLI

approved PeC - V. SCARIONI

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile