

test certificate of Type tests

apparatus MV, single core, XLPE insulated, power cable

designation PCM ELECTRIC CABLE 1/2001 TNBD 1Cx500 SQMM 22000 V
rated voltage 12/20(24) kV; rated normal current -- A; rated frequency -- Hz

manufacturer POWER CABLES MALAYSIA SDN BHD; Selangor; MALAYSIA

tested for POWER CABLES MALAYSIA SDN BHD; Selangor; MALAYSIA

date of tests from June 13 to August 02, 2001

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2 (11-1998)

this Test Certificate has been issued by CESI in accordance with above mentioned Standard.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date September 18, 2001

prepared PeC - E. Bertani

approved PeC - V. Scarioni

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio