

type test certificate of Breaking performance

apparatus Homogeneous series of back-up current limiting fuses

designation MG
 rated voltage 36 kV; rated normal current 16 A to 40 A; rated frequency 50 Hz
 The above values represent the minimum and the maximum ratings in a homogeneous series.
 Intermediate ratings of 20 A, 25 A and 30 A have been examined and comply with Clause 13.3.1 as part of this series.

manufacturer GURAL Elektrik Malzemeleri - Karakoy Istanbul - TURKEY

tested for GURAL Elektrik Malzemeleri - Karakoy Istanbul - TURKEY

date(s) of tests from June 21, 2001 to June 21, 2001

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60282-1 (1998) Clause 13

this Type Test Certificate has been issued by CESI following exclusively the STL Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date October 1, 2001

prepared PeC - P. BECCARINI

verified PeC - A. ELLI

approved PeC - V. SCARIONI

Giuseppe Beccarini
Antonio Elli

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit
 Prove e Componenti
 Il Responsabile del Laboratorio