

test certificate of Type tests

apparatus MV, single core 1x630 mm<sup>2</sup>, XLPE insulated, power cable

designation ELECTRIC CABLE 33 kV 1Cx630 SQMM 1997 UNIVERSAL CABLE (M) BHD  
rated voltage 18/30(36) kV; rated normal current -- A; rated frequency -- Hz

manufacturer UNIVERSAL CABLE (M) BERHAD; Johor Bahru; MALAYSIA

tested for UNIVERSAL CABLE (M) BERHAD; Johor Bahru; MALAYSIA

date of tests from October 12, 2001 to November 29, 2001

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2 (11-1998)

this Test Certificate has been issued by CESI in accordance with above mentioned Standard.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 4

issue date December 10, 2001

prepared PeC - E. Bertani

approved PeC - V. Scarioni

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio