

type test certificate of Dielectric, temperature rise and short-circuit performances

apparatus Three-pole horizontal 300 kV disconnecter fitted with earthing switch

designation GW4-300
rated voltage 300 kV; rated normal current 3150 A; rated frequency 50 Hz

manufacturer TENAGA SWITCHGEAR Sdn. Berhad - Selangor - MALAYSIA

tested for TENAGA SWITCHGEAR Sdn. Berhad - Selangor - MALAYSIA

date(s) of tests from February 16, 2001 to June 25, 2001

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60129 (1984) Sub-clauses 6.1, 6.2, 6.3, 6.4, 6.5, 6.102.3 and 6.104

this Type Test Certificate has been issued by CESI following exclusively the STL Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date December 11, 2001

prepared PeC - P. BECCARINI

verified PeC - E. FUSAR POLI

approved PeC - V. SCARIONI

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit
 Prove e Componenti
 Il Responsabile del Laboratorio