

test certificate of Test on electric cable under fire conditions

apparatus MV screened power cable, single core, XLPE insulated

designation Jeddah Cable Company 1x4/0 AWG 12/20 kV CU/XLPE/PVC
rated voltage 12/20 kV; rated normal current -- A; rated frequency -- Hz

manufacturer JEDDAH CABLE COMPANY - Jeddah; Saudi Arabia

tested for JEDDAH CABLE COMPANY - Jeddah; Saudi Arabia

date(s) of test March 14, 2000

the apparatus, constructed in accordance with the description, drawing and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC Technical Report 60332-3 (1992) Category C

this type test certificate has been issued by CESI in accordance with above mentioned standards.

the results are shown in the record of proving tests and the oscillograms attached in the test report. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the manufacturer as listed on page no.2 .

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date April 14, 2000

prepared TEST - E. Bertani

approved TEST - V. Scarioni



CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio