

test certificate of Routine and Type Tests (see test List Pg. 3)

apparatus Shunt capacitor for a.c. power system

designation Type TAF-T1325665S10R; Ser. N.T8Z1402S
rated voltage 10134 V; rated output 664,9 kVAR; rated frequency 50 Hz

manufacturer SAMWHA CAPACITOR CO. LTD - Yongin City;
Republic of Korea

tested for SAMWHA CAPACITOR CO. LTD - Yongin City;
Republic of Korea

date(s) of tests March 9 to 30, 2000

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with IEC Standard 60871-1 (1997)

this test certificate has been issued by CESI in accordance with above mentioned standard.

the results are shown in the record of proving tests and the oscillograms attached in the test report. The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on page no.2

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.


only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date April 12, 2000

prepared PeC - E. Bertani

approved PeC - V. Scarioni



CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

