

test certificate of dielectric and mechanical performance

apparatus cast resin insulated bushing for alternated voltages

designation 33kV/1250A  
rated voltage 33 kV; rated current 800/1250 A; rated frequency 50 Hz

manufacturer EPE POWER CORPORATION BERHAD - Kuala Lumpur (Malaysia)

tested for EPE POWER CORPORATION BERHAD - Kuala Lumpur (Malaysia)

date(s) of tests February 21 to 25, 2000

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with IEC 60137 (1995)

this test certificate has been issued by CESI in accordance with above mentioned standards.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the manufacturer as listed on page no.2

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 2

issue date April 18, 2000

prepared PeC - A. Sironi

approved PeC - V. Scarioni

*Alberto Sironi*

**CESI**

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio