

STLA

type test certificate of ability to withstand short-circuit

apparatus oil-immersed type transformer

designation E84.279
rated power 250 kVA; rated voltage 15/0.4 kV; rated frequency 50 Hz

manufacturer EFACEC ENERGIA, Máquinas e Equipamentos Electricos S.A.
S. Mamede de Infesta - PORTUGAL

tested for EFACEC ENERGIA

date(s) of tests May 24 to 26, 2000

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60076-5 (1976)

this type test certificate has been issued by CESI in accordance with the STL objectives and operating principles and under the terms of the STL agreement with the above mentioned standard following exclusively the STL guides.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on page no. 3.

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 4

issue date June 1, 2000

prepared TEST - V. Mantegazza

approved TEST - F. Pizzi


CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti