

test certificate of operating duty test
cable charging current interrupting test

apparatus automatic circuit recloser

designation EVR-3
rated voltage 38.0 kV; rated normal current 630 A;
rated frequency 50 Hz.

manufacturer ENTEC Electric & Electronic Company Ltd

tested for ENTEC Electric & Electronic Company Ltd

date(s) of tests July 18 to 21, 2000

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

ANSI C37-60 (1981) clause 6.3.4 and 6.12

this test certificate has been issued by CESI in accordance with above mentioned standards.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the manufacturer as listed on page no.2.

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date October 2, 2000

prepared P&C/Test - A. ELLI

approved P&C/Test - V. SCARIONI

Agostino ELLI

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio