

test certificate of Type Tests on accessories for power cables with extruded insulation

apparatus Outdoor cold-shrinkable single-core termination

designation UKB-36H2-120 Type 36 kV Outdoor Silicon
rated voltage 18/30 (36)kV; rated normal current -- A; rated frequency -- Hz

manufacturer ULUSOY - Electrical Marketing Industry & Trading Inc.
Sincan; Ankara - TURKEY

tested for ULUSOY - Electrical Marketing Industry & Trading Inc.
Sincan; Ankara - TURKEY

date(s) of tests June 11 to September 12, 2000

the apparatus, constructed in accordance with the description, drawing and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

CENELEC HD 629.1 S1 (1996)

this test certificate has been issued by CESI in accordance with above mentioned standard.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on page no.2 .

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 4

issue date October 11, 2000

prepared P.e C.\Test - E. Bertani

approved P.e C. - V. Scarioni



CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio