

test certificate of Type Tests

apparatus MV, three cores, 6/10 (12) kV, XLPE insulated, power cable

designation ALBORZ CABLE IEC 502 3x185/25 XLPE CABLE 10 kV MADE IN IRAN
rated voltage 6/10 (12) kV; rated normal current -- A; rated frequency -- Hz

manufacturer ALBORZ CABLE CO. - Teheran IRAN

tested for ALBORZ CABLE CO. - Teheran IRAN

date(s) of tests November 8 to December 11, 2000

the apparatus, constructed in accordance with the description, drawing and photograph incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with IEC 60502-2 (1998-11)

this type test certificate has been issued by CESI in accordance with the above mentioned standard.

the results are shown in the record of proving tests and the oscillograms attached in the test reports. The values obtained and the general performance are considered to comply with the above standard and to justify the ratings assigned by the manufacturer as listed on page no.2.

the certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer.

only integral reproduction of this certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 4

issue date December 13, 2000

prepared PeC - E. Bertani

approved PeC - V. Scarioni


CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio