

type test certificate of complete type tests
apparatus oil-immersed type transformer
designation EAC 200-22/11
 rated power 200 kVA; rated voltage 22/0.433 kV; rated frequency 50 Hz
manufacturer MINEL TRAF0 - Mladenovac (Yugoslavia)
tested for MINEL TRAF0 - Mladenovac (Yugoslavia)
date(s) of tests from July 29 to August 27, 2003
tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60076-2 (1993)
 IEC 60076-3 (2000)
 IEC 60076-5 (2000)

this Type Test Certificate has been issued by CESI following exclusively the STL Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page no. 2.

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3
issue date August 28, 2003
prepared PeC - M. Assolari
verified PeC - F. Pizzi
approved PeC - V. Scarioni

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit
 Prove e Componenti
 Il Responsabile del Laboratorio