

type test certificate of Switching performances

apparatus Three-pole SF6 gas-insulated dead-tank circuit-breaker with common operating mechanism

designation PASS M00
rated voltage 72,5 kV; rated normal current 2000 A; rated frequency 60 Hz

manufacturer ABB T&D S.p.A. - Unità operativa ADDA - Lodi - ITALY

tested for ABB T&D S.p.A. - Unità operativa ADDA - Lodi - ITALY

date(s) of tests from April 7, 2003 to April 10, 2003

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-100 (2001)

Sub-clause 6.111 (line-charging and cable-charging)

this Type Test Certificate has been issued by CESI following exclusively the STB Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Report. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date June 9, 2003

prepared PeC - P. BECCARINI

verified PeC - F. LO MONACO

approved PeC - V. SCARIONI

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio