

test certificate of Lightning test - first stroke

apparatus Grounding Kit

designation LCF 1"-5/8 45°
Rated impulse current 100 kA; Charge 50 C; Action integral 2.5 MA² × s

manufacturer CPE S.p.A - Milano - ITALY

tested for CPE S.p.A - Milano - ITALY

date(s) of tests from March 20, 2003 to March 21, 2003

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 61312-1 (1995)

this Test Certificate has been issued by CESI in accordance with above mentioned Standards.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date June 23, 2003

prepared PeC - R. Malgesini

verified PeC - V. Scarioni

approved PeC - V. Scarioni



CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio