

type test certificate of Verification of short-circuit withstand strength

apparatus Three-phase with neutral bar resin busducts

designation BR 1600S - BR 3150D

manufacturer Gital Co. - Tehran - IRAN

tested for Gital Co. - Tehran - IRAN

date(s) of tests August 4, 2003

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60439-2 (2000-03) Sub-clause 8.2.3

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no.2 .

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 2

issue date September 19, 2003

prepared PeC - C. Del Giorgio

verified PeC - A. Elli

approved PeC - V. Scarioni

Carlo Del Giorgio
Apostino

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit
 Prove e Componenti
 Il Responsabile del Laboratorio