

Type Test Certificate of Switching performances

Apparatus Pole of a three-pole SF6 circuit-breaker

Designation SB6m  
Rated voltage 145 kV ; Rated normal current 3150 A ; Rated frequency 50 Hz

Manufacturer Nuova Magrini Galileo S.p.A. - Member of VA TECH Schneider  
High Voltage Group - Italy

Tested for VA TECH - Italy

Date(s) of tests from July 11, 2001 to July 18, 2001

Tested by CESI S.p.A. - Milano - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 62271-100 (2001)**

Sub-clauses 6.111 (line-charging, cable-charging and single-capacitor bank)

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.


No. of pages 3

Issue date November 13, 2003

Prepared PeC - P. BECCARINI

Verified PeC - P. GRAMAGLIA

Approved PeC - V. SCARIONI



**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio