

Type Test Certificate of	Dielectric Performance
Apparatus	Three-pole SF6 gas-insulated general purpose class E3 switch fitted with earthing switch set in a metal enclosed switchgear
Designation	FLUSARC F Rated voltage 24 kV ; Rated normal current 630 A ; Rated frequency 50 Hz
Manufacturer	VEI POWER DISTRIBUTION S.p.A. - Guardamiglio (LO) - ITALY
Tested for	VEI POWER DISTRIBUTION S.p.A. - Guardamiglio (LO) - ITALY
Date(s) of tests	from March 5, 2001 to July 16, 2001
Tested by	CESI S.p.A. - Milano - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60265-1 (1998)
Sub-clause 6.2

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages	3
Issue date	October 15, 2003
Prepared	PeC - P. BECCARINI
Verified	PeC - A. GEROLI
Approved	PeC - V. SCARIONI

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio