

type test certificate of short-circuit performance

apparatus oil-immersed transformer

designation 1000-123  
rated power 1000 kVA; rated voltage 33,0,433 kV; rated frequency 50 Hz

manufacturer MALAYSIA TRANSFORMER MANUFACTURING - Kuala Lumpur (Malaysia)

tested for MALAYSIA TRANSFORMER MANUFACTURING - Kuala Lumpur (Malaysia)

date(s) of tests from March 23 to 29, 2004

tested by CESI S.p.A. - Milano - ITALY

the apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference document, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60076-5 (2000)

this Type Test Certificate has been issued by CESI following exclusively the STL Guides.

the results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the Manufacturer as listed on page no. 2.

the Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

no. of pages 3

issue date April 2, 2004

prepared PeC - M. Assolari

verified PeC - F. Pizzi

approved PeC - M. de Nigris

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio