

Type Test Certificate of Complete type tests

Apparatus Three-pole SF6 general purpose switch for grounded and ungrounded neutral systems

Designation GLBS-3M
Rated voltage 33 kV ; Rated normal current 400 A ; Rated frequency 50 Hz

Manufacturer THAI MAXWELL ELECTRIC Co., Ltd - THAILAND

Tested for THAI MAXWELL ELECTRIC Co., Ltd - THAILAND

Date(s) of tests from July 1, 2004 to February 1, 2005

Tested by CESI S.p.A. - Milano - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60265-1 (1998)

Sub-clauses 6.2, 6.4, 6.5, 6.6, 6.7 and 6.101

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date February 16, 2005

Prepared PeC - P. BECCARINI

Verified PeC - A. GEROLI

Approved PeC - M. de NIGRIS

Giuseppe Motta
PeC

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio