

Test Certificate of Type tests, electrical
Type tests, non electrical

Apparatus MV cable Cu/XLPE/PE/SWA/PE, 3x240 mm², armoured

Designation Rated voltage 6/10 kV ; Rated normal current -; Rated frequency -

Manufacturer ILJIN ELECTRIC CO., LTD.; HWASUNG-KUN KYUNGGI-DO; SOUTH KOREA

Tested for ILJIN ELECTRIC CO., LTD.; HWASUNG-KUN KYUNGGI-DO; SOUTH KOREA

Date(s) of tests from February 4, 2005 to February, 2005

Tested by CESI S.p.A. - Milano - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60502-2 (1998-11)
Clauses 18 and 19


The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date April 13th, 2005

Prepared PeC - L.Arosio 

Approved PeC - M. de Nigris

CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

