

Test Certificate of Type tests on cable

Apparatus Single core XLPE power cable

Designation FDP-3 2004 132 kV 1C x 800 mm² SESB
Rated voltage 76 132kV

Manufacturer FEDERAL POWERSDN BHD – Selangor Darul Ehsan - MALAYSIA

Tested for FEDERAL POWERSDN BHD - Selangor Darul Ehsan - MALAYSIA

Date(s) of tests from February 28th, 2005 to April 26th, 2005

Tested by CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60840 Third edition 2004-04
Clauses 13

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date May 4th, 2005

Prepared PeC - L.Arosio – M.Nervetti



Approved PeC - M. de Nigris

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

