

Type Test Certificate of Dielectric performance

Apparatus Three-pole SF6 general purpose switch for grounded neutral systems

Designation RL2
Rated voltage 38 kV ; Rated normal current 630 A ; Rated frequency 50 Hz

Manufacturer NU-LEC industries Pty Ltd. – Lytton Queensland - Australia

Tested for NU-LEC industries Pty Ltd. – Lytton Queensland - Australia

Date(s) of tests from March 9, 2005 to March 11, 2005

Tested by CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60265-1 (1998)
Sub-clauses 6.2

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages

2

Issue date

July 8, 2005

Prepared

PeC - P. BECCARINI

Verified

PeC - A. SIRONI

Approved

PeC - M. de NIGRIS

CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit

Prove e Componenti
Il Responsabile del Laboratorio