

Type Test Certificate of Dielectric, Temperature-rise and Short-circuit Performances

Apparatus Three-pole horizontal disconnecter

Designation NSA 72,5 / 3150D
Rated voltage 72,5 kV ; Rated normal current 3150 A ; Rated frequency 50 Hz

Manufacturer PARS SWITCH Co. – Zanjan - IRAN

Tested for PARS SWITCH Co. – Zanjan - IRAN

Date(s) of tests **from** January 20, 2006 **to** February 15, 2006

Tested by CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-102 (2003)
Clauses 6.2, 6.4 to 6.6

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages

3

Issue date

July 31, 2006

Prepared

BU COM - E. D'ADDA

Verified

BU COM - F. LO MONACO

Approved

BU COM - V. SCARIONI

CESI
Centro Elettrotecnico Sperimentale Italiano
Giacinto Motta SpA
Business Unit Electrical Components Qualification
The Manager

Virgilio Scarioni