

**Type Test Certificate of** Short-circuit and switching performances

**Apparatus** Three-pole SF6 gas-insulated line disconnecter with common enclosure and operating mechanism, for installation in GIS configuration

**Designation** GWG1-145  
Rated voltage 145 kV ; Rated normal current 3150 A ; Rated frequency 50 Hz

**Manufacturer** XI'AN SHIKY High Voltage Electric Co. Ltd. – XI'AN - P.R. CHINA

**Tested for** XI'AN SHIKY High Voltage Electric Co. Ltd. – XI'AN - P.R. CHINA

**Date(s) of tests** **from** December 22, 2004 **to** June 24, 2005

**Tested by** CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 62271-102 (2003)  
Sub-clauses 6.6 and 6.106**

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages**

3

**Issue date**

April 3, 2007

**Prepared**

AREA COM - P. BECCARINI

**Verified**

AREA COM - F. LO MONACO

**Approved**

AREA COM - V. SCARIONI

**CESI**  
Centro Elettrotecnico Sperimentale Italiano  
Giacinto Motta SpA  
Business Unit Electrical Components Qualification  
The Manager  
*Virginia Scarioni*