

**Test Certificate of** complete type tests

**Apparatus** inductive voltage transformer

**Designation** VRQ2n/S2  
Rated voltages 23: $\sqrt{3}$  kV/ 100: $\sqrt{3}$  - 100:3 V ; Rated frequency 50 Hz

**Manufacturer** SCHNEIDER ELECTRIC S.p.A. – Bragno, Cairo Montenotte (SV) – Italy

**Tested for** SCHNEIDER ELECTRIC S.p.A. – Bragno, Cairo Montenotte (SV) – Italy

**Date(s) of tests** **from** February 16, 2006 **to** September 14, 2006

**Tested by** CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 60044-2 (2003)**

This Type Test Certificate has been issued by CESI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

PUBBLICATO A6026155 (PAD - 842307)

**No. of pages** 3

**Issue date** October 10, 2006

**Prepared** BU COM - C. Del Giorgio

**Verified** BU COM - F. Pizzi

**Approved** BU COM - V. Scarioni

**CESI**  
 Centro Elettrotecnico Sperimentale Italiano  
 Giacinto Motta SpA  
 Business Unit Electrical Components Qualification  
 The Manager  
*Vinguescanar*