

**Type Test Certificate of** Complete Type Tests

**Apparatus** Pole of live tank SF6 circuit-breaker

**Designation** OFPI-550-63L-HAR  
Rated voltage 550 kV ; Rated normal current 6000 A ; Rated frequency 50 Hz

**Manufacturer** Chung-Hsin Electric & Machinery MFG Corp.  
No.25 Wen-Te Rd., Kwei-Shan Hsiang, Taoyuan Hsein, Taiwan, R.O.C

**Tested for** Chung-Hsin Electric & Machinery MFG Corp.  
No.25 Wen-Te Rd., Kwei-Shan Hsiang, Taoyuan Hsein, Taiwan, R.O.C

**Date(s) of tests** **from** November 6, 2006 **to** March 1, 2007

**Tested by** CESI S.p.A. - Milano - ITALY  
FGH-Engineering & Test GmbH - Mannheim - GERMANY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 62271-100 (2006), Clause 6**  
**IEC 62271-110 (2005), Clause 6.115**

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 3

**Issue date** April 14, 2008

**Prepared** Unit LABORATORIES - P. Beccarini

**Verified** Unit LABORATORIES - F. Lo Monaco

**Approved** Unit LABORATORIES - R. Nicolini

**CESI** S.p.A.  
Energy Division  
Technical Area Components  
"Testing Laboratories"  
Manager