

**Test Certificate of** tests to prove suitability to short-circuit withstand strength and effectiveness of the protective circuit

**Apparatus** Low-voltage switchgear assembly

**Designation** 6-Way Feeder Pillar  
Rated current 2500 A ; Rated operational voltage 415 V ; Rated frequency 50 Hz

**Manufacturer** AL-AHLEIA Switchgear Co. – Kuwait

**Tested for** AL-AHLEIA Switchgear Co. – Kuwait

**Date(s) of tests** from April 16, 2008 to April 16, 2008

**Tested by** IPH GmbH – Berlin – Germany

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 60439-1 (2004)**

This Test Certificate has been issued by CESI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 3

**Issue date** May 21, 2008

**Prepared** Unit LABORATORIES - F. Pizzi

**Approved** Unit LABORATORIES - R. Nicolini

**CESI** S.p.A.  
Energy Division  
Technical Area Components  
"Testing Laboratories"  
Manager