Test Certificate of

November 20, 2007



Verification of conformity to the manufacturing drawings and to characteristics of the

circuit-breaker Mechanical operation Dielectric tests Temperature-rise test

Verification of the adjustment of the relays and releases

Electrical endurance Mechanical endurance

Verification of the making and breaking capacity in short-circuit conditions

Search of critical currents and low current test duty

Apparatus D.C. circuit breaker

Designation UR26-81 S

Rated voltage (U_{Ne}) 900 V; Rated insulation voltage (U_{N}

Conventional thermal current (Ith, Ithe) 2600 A

Manufacturer SECHERON S.A.

Tested for SECHERON S.A. – GENEVE (Switzer)

Date(s) of tests from February 16, 2005

CESI S.p.A. - Milano - I Tested by

ptographs incorporated in the reference documents, identified in The apparatus, constructed in accordance with the description, drawing and pl this certificate, has been subjected to the series of proving tests in accordar

> CEI EN 6199 **2(**2006-02)

3.1, 8.3.2, 8.3.3, 8 4, 8.3.5, 8.3.6, 8.3.7, 8.3.8, 8.3.10 Sub-clauses

This Test Certificate has been issued by C SI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rest with the Manafacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date April 28, 2008

Prepared Unit LABORATORIES - F. Pizzi

Approved Unit LABORATORIES - R. Nicolini Area Components aboratories"