

Type Test Certificate of Complete Type Tests

Apparatus Pole of live tank SF6 circuit-breaker

Designation OFPI-550-63L-HAR
Rated voltage 550 kV ; Rated normal current 6000 A ; Rated frequency 50 Hz

Manufacturer Chung-Hsin Power Systems (JiangSu) Inc.
Industrial Park, Huolong Town, Haimen City, Jiang-Su, 226144, China

Tested for Chung-Hsin Power Systems (JiangSu) Inc.
Industrial Park, Huolong Town, Haimen City, Jiang-Su, 226144, China

Date(s) of tests **from** November 6, 2006 **to** March 1, 2007

Tested by CESI S.p.A. - Milano - ITALY
FGH-Engineering & Test GmbH - Mannheim - GERMANY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-100 (2006), Clause 6
IEC 62271-110 (2005), Clause 6.115

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date June 11, 2008

Prepared LAP - Beccarini Pierangelo
A8015757 2925 ALP

Verified LAP - Arneodo Giorgio, LAP - Lo Monaco Franco
A8015757 503476 VER A8015757 2896 VER

Approved LAP - Nicolini Roberto
A8015757 821814 APP

CESI S.p.A.
Energy Division
Technical Area Components
"Testing Laboratories"
Manager

