

Type Test Certificate of Complete type tests

Apparatus Oil-immersed power transformer

Designation 1500 kVA silicone oil transformer
Rated power 1500 kVA ; Rated voltages 11,3/0,39 kV ; Rated frequency 50 Hz

Manufacturer ABB Shanghai Transformer Co., LTD – Shanghai – P. R. China

Tested for ABB Shanghai Transformer Co., LTD – Shanghai – P. R. China

Date(s) of tests from July 7, 2008 to July 18, 2008

Tested by CESI S.p.A. – Milano – ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60076-2 (1993)
IEC 60076-3 (2000), clause 13
IEC 60076-5 (2006)

This Type Test Certificate has been issued by CESI following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2 .

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3

Issue date July 24, 2008

Prepared LAP - Assolari Mauro
A8021797 2983 AUT

Verified LAP - Pizzi Franco
A8021797 3019 VER

Approved LAP - Nicolini Roberto
A8021797 821814 APP

CESI S.p.A.
Energy Division
Technical Area Components
"Testing Laboratories"
Manager